



AREA	Type	Volts	Amps	S.P.	CFM	BTU	KW	O.A.
F- Dining	AHU #2	208/230-3	N/A	.1	1600	48,000	Existing Unit	
Office	AHU #3	208/230-3	N/A	.1	1600	48,000	Existing Unit	
R- Dining	AHU #4	208/230-3	N/A	.1	1200	36,000	Existing Unit	
Kitchen	AHU #5	208/230-3	N/A	.1	2800	96,000	Existing Unit	N/A
Bath Rooms	EF#3	120-1	.75	.250	350	n/a	n/a	n/a

Air Diverse Schedule

6" = 50 to 140 CFM	12" = 401 to 650 CFM
8" = 141 to 275 CFM	14" = 651 to 900 CFM
10" = 276 to 400 CFM	16" = 901 to 1200 CFM

BROTHER'S MECHANICAL / STEPHEN M. SMITH
 CLASS A CONTRACTOR : 2705115413
 HVAC TRADESMAN : 2710045743

7218 Twin Cedars Dr. Woodford Va. 22580
 540-898-6339